

GOVERNMENT OF JAMMU AND KASHMIR
OFFICE OF THE DEPUTY DIRECTOR FIRE & EMERGENCY SERVICES
COMMAND ANANTNAG

The Additional Deputy Commissioner,
Anantnag.

No: - DDA/FP/NOC/ 2019/ 301

Dated: 25-3-2019

Subject: - NOC in respect of Army Good will Public School Pahalgam for storage of K.Oil.

Reference: - Deputy Commissioner Office letter number NO:DCA/SS/2018-19/1190-1200 dated
14.03.2019

Sir,


No objection certificate is hereby granted in favour of Army Good will Public School
Pahalgam for storage of a K. Oil subject to the fulfillment of following safety measures:-


1. That the installation shall be on roadside so that the fire appliance can reach on spot.
2. That the installation shall be located well away from the residential area.
3. That the storage tank shall be made of 26 swg iron sheet.
4. That the refilling of K. Oil shall not be made between the sunset and sunrise.
5. A notice board displaying "No Smoking" shall be placed near the outlet.
6. No. electric line HT/LT shall pass over the outlet.

RECOMMENDATIONS FOR FIRST AID FIRE FIGHTING INSTALLATIONS

1. Two numbers of 09 Kg capacity foam type fire extinguishers shall be installed as per IS 933-1989.
2. Two DCP type fire extinguishers of 06 Kg capacity shall be installed as per IS 1271-1985.
3. Four Nos. of GI Fire buckets filled with lose sand of 12 KG capacity shall be installed as per IS 2546-1993.
4. Two (2) Nos. of shovels shall be kept within the out let.
5. Good Housekeeping should be maintained in and around the outlet.

Yours faithfully,


Deputy Director,
Fire & Emergency Services
Command Anantnag.
23/03/2019


PRINCIPAL
Army Goodwill Public Schoc
Affiliated to C.B.S.E. No. 73005
Sidru, Pahalgam Anantnag / J&K