

**Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar**

The Principal,
Army Goodwill Public School,
Lidroo Pahalgam Anantnag.

No: DFES/FP/9/2024-04/CC-7079422-9941

Dated. (J) : 05:2026.

Sub: - Fire & life safety measures/ guidelines in favour of Army Goodwill Public School situated at Lidroo Pahalgam Anantnag.

Refnce: Your online application submission date, 10-04-2026 Tracking Id No.PF012-78672402.

The inspection of above said school was got carried out by the Deputy Director F&ES Command Anantnag and found that the school is situated at Lidroo Pahalgam Anantnag & is 08 Km away from F&ES Station Pahalgam is accessible for fire tenders in case of emergency. The detailed report with fire safety precautionary measures/guidelines are as under:-

1. **Block "A"**:- is double storeyed building (G+1) CGI sheet roofed over wooden truss having four staircase of 1.07 meter wide. Ground floor comprises of 08 class rooms, 08 labs, 05 office rooms, boiler room. 1st floor comprises of 08 class rooms, staff room, art room, computer room, museum room, atal trunking room and exam hall.

2. **Block "B"**:- is 2-storeyed CGI sheet roofed over wooden truss having three staircase. Ground floor comprises of 04 dormitory 20 bedded, prayer room, AV room, dining room, dining hall, kitchen, dry store and store room. 1st floor comprises of 04 dormitory barracks 20 bedded each double decker and study room.

3. **Block "C"**:- is 2-storeyed building CGI sheet roofed having three staircase. Ground floor comprises of 04 dormitory 20 bedded, prayer room, store room and non functional dining hall. 1st floor comprises of 04 dormitory barracks 20 bedded each double decker and study room.

single storeyed building CGI sheet roofed over wooden truss comprises upon 03 laboratory rooms.


4. **Block "D"**:- is single storeyed building CGI sheet roofed over wooden truss comprises of doctors room and hall.

5. **Block "E"**:- is single storeyed building CGI sheet roofed over wooden truss comprises of laundry room.

6. Existing Firefighting facilities:- nil

Recommendations :-

1. 02 unit each water type 09 liters/ 02 unit of CO2 type/ 02 unit of water type capacity fire extinguishers shall be provided in all the building, in addition to already existing fire extinguishers.
2. Hose reel as per BIS specifications connected with the terrace tank of 10,000 Ltrs. Capacity shall be provided in all the double storeyed buildings. The Hose Reel shall be kept at such a place where from every nook and corner of each floor of school building are covered easily at the time of any emergency. A Fire Pump of desired capacity shall be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel.
3. Yard Hydrants shall be provided in the school premises connected with underground water tank of 10,000 liters fitted with electric pump.
4. Illuminated exit signs in all building shall be clearly marked to lead the occupants to the place of ultimate safety. All exits including corridors, staircases, passage ways etc shall have provision of alternate emergency lighting. These lights shall automatically switch on upon the failure of the main power supply.
5. Wooden components of the all combustible material like wood etc. need to be replaces by noncombustible material or in alternatively fire retardant paint of two hours rating shall be given for wooden components.
6. The exits shall allow free access for fire tenders in case of emergency.
7. All escape routes shall be kept free from any obstructions to provide hindrance free escape in case of emergency besides all doors, gates shall be kept unlocked during the occupancy of the college building.
8. Examination/ computer hall & class rooms having capacity of more than 45 students shall have at least two exits. Space under the escape routes at ground level if used as electric control panel shall not be allowed.
9. Attic portion of the building shall not be used for any kind of storage. Grill fitted in the windows essentially in ground floor shall be removed. Fire/Evacuation drill shall be conducted regularly.
10. Employees of the school shall be trained for maintenance & use of fire fighting equipments.
11. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel etc.) Any deviation found in this regard, these fire and life safety measures/ guidelines issued will be treated automatically withdrawn/cancelled.
12. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
13. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, these fire and life safety measures/ guidelines issued shall be treated automatically withdrawn/cancelled.
14. The students of preschool, kindergarten, up to class 1st shall be accommodated on ground floor and class 2nd students shall be accommodated not above 1st floor of the building.
15. These fire & life safety measures/guidelines shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire & life safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued. Furthermore the status with regards to land shall be the responsibility of the concerned registering authority.
16. The instant fire safety measures is strictly for adoption of fire safety recommendations/guidelines of the occupancy only and not for authentic ation of any other claim.
17. While issuing final registration /permission to above said establishment, the authority concerned may ensure the fire safety recommendation/guidelines given to the school by this department are fully complied with.
18. These fire & life safety measures/guidelines are issued in respect of the institution with a validity of two years for adoption & same needs to be renew after inspection/checking of entire fire fighting system installed in the school (ie existing as well as proposed by the technical officer of this department. However, before granting permission/recognition/extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO-292 of 2016, issued by Education Department with regard to Physical facilities.


Director,
Fire & Emergency Services, J&K,
Jammu/Srinagar